

Message Text

UNCLASSIFIED

PAGE 01 MOSCOW 05420 211341Z
ACTION EUR-12

INFO OCT-01 ISO-00 FBOE-00 SY-05 OC-06 CCO-00 /024 W
-----220406Z 043768 /20

R 211306Z APR 77
FM AMEMBASSY MOSCOW
TO SECSTATE WASHDC 6521

UNCLAS MOSCOW 5420

FOR: EUR/EX FOR BASKEY, EUR/SOV FOR BARRY, A/FBO FOR STRANGE AND
MORRISON, A/SY FOR HANRAHAN, A/OC FOR GAIN

E.O. 11652: N/A

TAGS: AFSP, ABLD, ASEC, ACOM, UR, US

SUBJ: TECHNICAL DOCUMENTATION FOR STRELETSKAYA BUILDINGS IN KIEV

1. KAP'S WHITE AND KIEV'S REPUBLIC PLANNING INSTITUTE PROJECT
ENGINEER KOSTYUCHENKO MET APRIL 12 TO DISCUSS TECHNICAL DOCUMENTA-
TION WHICH SOVIET SIDE REQUIRES FOR THEIR PLANNING. THE BASIS FOR
THE DISCUSSION WAS THE BOOK "ELECTRICAL EQUIPMENT, US GOVERNMENT
FURNISHED, FOR US CONSULATE GENERAL, GORKIY/STRELETSKAYA, KIEV,
USSR" DATED MARCH 9, 1977 AND PREPARED BY MR. KNOOP, WHICH WAS PRE-
SENTED TO UPKK APRIL 4.

2. THE FOLLOWING INFORMATION MUST STILL BE PROVIDED TO UPKK. KAP
REQUESTS THAT IT BE FORWARDED ASAP.

3. ELECTRIC PANELS.

A. MDP. NOTHING SHOWN IN "SQUARE D" CATALOGUE ABOVE 225 AMPS
THAT WOULD COVER 240/415 VOLT, 3-PHASE, 4-WIRE 1000 AMB MAIN.
PLEASE ADVISE OR PROVIDE.

B. PBC. PLEASE ADVISE OR PROVIDE DATA FOR 400 AMP
MAIN.

UNCLASSIFIED

UNCLASSIFIED

PAGE 02 MOSCOW 05420 211341Z

C. PIE, P2E, P3D, E. KAP TOLD RPI THESE WOULD BE CATALOGUE
NO. Q0442E, BOX 10. PLEASE CONFIRM.

D. P2D, P3B, P4B, P1C, P2C, P3C, P4A, P1A, P2A, P2B, P3A, P3B.
KAP TOLD RPI THESE WOULD BE CATALOGUE NO. Q412E, BOX 7. PLEASE
CONFIRM.

E. PID. KAP TOLD RPI THIS WOULD BE CATALOGUE NO. Q0420E,
BOX 8. PLEASE CONFIRM.

F. PBA, PBB. KAP TOLD RPI THESE WOULD BE CATALOGUE NO.
Q0440MW225E, BOX 25. PLEASE CONFIRM.

G. PBD. KAP TOLD RPI THIS WOULD BE CATALOGUE NO. Q0424M100E,
BOX 9. PLEASE CONFIRM.

4. VOLTAGE REGULATOR. CATALOGUE DOES NOT SHOW 220/
380 VOLT TYPE. PROVIDE CATALOGUE NO. OR NEW CATALOGUE PAGE.

5. PLEASE PROVIDE CATALOGUE PAGES FOR THE FOLLOWING:

A. 1000-AMP, 3-POLE FUSED SWITCH (AT VOLTAGE REGULATOR);

B. 100-AMP, 600-VOLT, 3-POLE FUSED SWITCH FOR ELEVATOR;

C. 15, 30 AND 60-AMP, 240-VOLT, 1-POLE WALL OUTLETS;

D. 20 AND 60-AMP, 240-VOLT, 3-POLE WALL OUTLETS;

E. 20-AMP, 240-VOLT SINGLE-POLE SWITCH;

F. 20-AMP, 240-VOLT, 3-POLE SWITCH;

G. 20-AMP, 240-VOLT, 4-POLE SWITCH;

H. 20-AMP, 240-VOLT, SINGLE-POLE DIMMERSWITCH;
UNCLASSIFIED

UNCLASSIFIED

PAGE 03 MOSCOW 05420 211341Z

I. "DRILL" SWITCH;

J. ELEVATOR LIGHTING AND TELEPHONE CONNECTION PANEL;

K. MOTORIZED MOVIE SCREEN;

L. VENTILATING STOVE HOODS;

M. CARRIER CORP AIR CONDITINERS;

N. DOORBELL AND DOORBELL TRANSFORMERS;

O. COMBINATION FLOOR BOX WITH TELEPHONE OUTLET AND 20-AMP,
240-VOLT, 1-PHASE RECEPTABLE;

P. ENTIRE EMERGENCY ALARM PANEL.

6. FIRE ALARM PANEL.

A. WHICH CONTROL UNIT WILL BE USED?

B. WHICH ENCLOSURES WILL BE USED?

C. IS "MARCH TIME MODULE" USED, AND HOW DOES IT FIT INTO SYSTEM?

D. PLEASE PROVIDE CATALOGUE PAGE OF SFA-703 PROGRAM MODULE
(ONLY SFA-701 WAS SENT).

7. FIRE ALARM STATION.

A. PLEASE PROVIDE DIMENSIONS OF UNIT;

B. PLEASE SEND "FIGURE 2" WITH THE MOUNTING INSTRUCTIONS.

UNCLASSIFIED

UNCLASSIFIED

PAGE 04 MOSCOW 05420 211341Z

8. EMERGENCY ALARM BELL. PLEASE PROVIDE CATALOGUE PAGE FOR
SAU 2-11.

9. GENERATOR. PLEASE PROVIDE ALL HOLD-DOWN PAD, BOLTS AND OTHER
INSTALLATION REQUIREMENTS FOR GENERATOR.

10. PLEASE PROVIDE INFORMATION ON WHERE "MAIN DISCONNECT SWITCH"
AND "GROUND FAULT DETECTOR" ARE TO BE INSTALLED.
TOON

UNCLASSIFIED

NNN

Message Attributes

Automatic Decaptioning: X
Capture Date: 01-Jan-1994 12:00:00 am
Channel Indicators: n/a
Current Classification: UNCLASSIFIED
Concepts: n/a
Control Number: n/a
Copy: SINGLE
Sent Date: 21-Apr-1977 12:00:00 am
Decaption Date: 01-Jan-1960 12:00:00 am
Decaption Note:
Disposition Action: n/a
Disposition Approved on Date:
Disposition Case Number: n/a
Disposition Comment:
Disposition Date: 01-Jan-1960 12:00:00 am
Disposition Event:
Disposition History: n/a
Disposition Reason:
Disposition Remarks:
Document Number: 1977MOSCOW05420
Document Source: CORE
Document Unique ID: 00
Drafter: n/a
Enclosure: n/a
Executive Order: N/A
Errors: N/A
Expiration:
Film Number: D770139-0973
Format: TEL
From: MOSCOW
Handling Restrictions: n/a
Image Path:
ISecure: 1
Legacy Key: link1977/newtext/t19770434/aaaabcqy.tel
Line Count: 148
Litigation Code IDs:
Litigation Codes:
Litigation History:
Locator: TEXT ON-LINE, ON MICROFILM
Message ID: da5330a1-c288-dd11-92da-001cc4696bcc
Office: ACTION EUR
Original Classification: UNCLASSIFIED
Original Handling Restrictions: n/a
Original Previous Classification: n/a
Original Previous Handling Restrictions: n/a
Page Count: 3
Previous Channel Indicators: n/a
Previous Classification: n/a
Previous Handling Restrictions: n/a
Reference: n/a
Retention: 0
Review Action: RELEASED, APPROVED
Review Content Flags:
Review Date: 12-Oct-2004 12:00:00 am
Review Event:
Review Exemptions: n/a
Review Media Identifier:
Review Release Date: n/a
Review Release Event: n/a
Review Transfer Date:
Review Withdrawn Fields: n/a
SAS ID: 2738556
Secure: OPEN
Status: NATIVE
Subject: TECHNICAL DOCUMENTATION FOR STRELETSKAYA BUILDINGS IN KIEV
TAGS: AFSP, ABLD, ASEC, ACOM, UR, US
To: STATE
Type: TE
vdkgvwkey: odbc://SAS/SAS.dbo.SAS_Docs/da5330a1-c288-dd11-92da-001cc4696bcc
Review Markings:
Margaret P. Grafeld
Declassified/Released
US Department of State
EO Systematic Review
22 May 2009
Markings: Margaret P. Grafeld Declassified/Released US Department of State EO Systematic Review 22 May 2009